

| [NRC Home](#)

SEQNOS QUERY RESULTS

[BACK TO ENTER QUERY](#) [CREATE NEW QUERY](#)

1 - 2

[Click here to view query results in spreadsheet](#)

View Report	Materials Page	NRC Report #	Type of Call	Date/Time Received	Description Of Incident	Type Of Incident	Incident Cause	Incident Date/Time	Location	State	Nearest City	County	Suspected Responsible Company	Medium Affected	Material Name
View	Materials	916122	INCIDENT	27-AUG-2009 11:20	NATURAL GAS RELEASED THROUGH COMPRESSOR STATION EMERGENCY SHUT DOWN SYSTEM ALONG WITH SOME LUBE OIL WHICH HAS FALLEN ON PRIVATE PROPERTY. A CRACK IN A 1-INCH DIAMETER NIPPLE CAUSED RELEASE OF NATURAL GAS WHICH CAUSED THE EMERGENCY SHUTDOWN. EXPECTED CLEAN UP TO PRIVATE PROPERTY MAY EXCEED \$50,000.	PIPELINE	EQUIPMENT FAILURE	23-AUG-2009 14:00	COMPRESSOR STATION 4 MILES SOUTH EAST OF CLEARVILLE, PA ON ROCKHILL CHURCH ROAD STECKMAN RIDGE	PA	CLEARVILLE	BEDFORD	SPECTRA ENERGY	UNKNOWN	NATURAL GAS
View	Materials	916122	INCIDENT	27-AUG-2009 11:20	NATURAL GAS RELEASED THROUGH COMPRESSOR STATION EMERGENCY SHUT DOWN SYSTEM ALONG WITH SOME LUBE OIL WHICH HAS FALLEN ON PRIVATE PROPERTY. A CRACK IN A 1-INCH DIAMETER NIPPLE CAUSED RELEASE OF NATURAL GAS WHICH CAUSED THE EMERGENCY SHUTDOWN.	PIPELINE	EQUIPMENT FAILURE	23-AUG-2009 14:00	COMPRESSOR STATION 4 MILES SOUTH EAST OF CLEARVILLE, PA ON ROCKHILL CHURCH ROAD STECKMAN RIDGE	PA	CLEARVILLE	BEDFORD	SPECTRA ENERGY	UNKNOWN	OIL, MISC: LUBRICATING

SEQNOS QUERY RESULTS																			
				EXPECTED CLEAN UP TO PRIVATE PROPERTY MAY EXCEED \$50,000.															
Click here to view query results in spreadsheet																			
1 - 2																			
BACK TO ENTER QUERY CREATE NEW QUERY																			